

OGC Case No.: 22-1794 Exhibit B Sanitary Sewer Overflow (SSO) Reporting Summary

Spill Date	Reported Date	Location	SSO Volume (gal.)	Recovered Volume (gal.)	Discharge Character	Cause	Affected Area
9/4/2023	9/5/2023	4 SE 21st Ave. S	200		Raw Water	ARV damaged by Accident	Meade Canal
7/17/2023	7/17/2023	6 Burnt Store Rd.	100	50	Raw Water	ARV damaged by Accident	Shadroe Lake
6/14/2023	6/14/2023	4901 Normandy Ct.	50,000	30,000	Raw Water	Bypass pump failure MS 103, Equipment	20,000 gal entered canal
3/7/2023	3/8/2023	917 NE Pine Island Ln.	200	900	Raw Water	ARV damaged by mowing Contractor	Ground
2/23/2023	2/23/2023	400 W Kennedy Lake Dr.	200		Raw Water	Small Lift Station pump power turned off by Contractor	Ground
11/7/2022	11/8/2022	3014 Chiquita Blvd.	200	100	Raw Water	ARV damaged by Contractor	SW (Killer Lake)
10/15/2022	10/18/2022	4318 SW 9th Ave.	450	4,000	Raw Water	Force Main damaged by directional drill Contractor	Ground
9/15/2022	9/16/2022	423 SE 26th Terr.	10,000		Reclaimed Water	Irrigation Main damaged by Contractor	Ground
9/10/2022	9/12/2022	4411 Skyline Blvd.	882,353		Reclaimed Water	Irrigation Main pipe failure, Equipment	SW (Caloosahatchee Estuary)
8/3/2022	8/3/2022	4901 Del Prado Blvd. S.	7,500	9,500	Raw Water	Bypass pump failure MS 103, Equipment	SW (Caloosahatchee Estuary)
7/31/2022	8/1/2022	1600 Cape Coral Pkwy. E.	500	1500	Raw Water	Lift Station 103 pump capacity exceeded due to excessive Rain	Ground

7/13/2022	7/15/2022	1803 Cape Coral Pkwy. W.	105,844		Reclaimed Water	Contractor	SW (Cape Coral Tidal Segment) Rockview Canal
6/27/2022	7/1/2022	1003 Santa Barbara Blvd.	50	50	Raw Water	Equipment (ARV leaking)	Ground
6/7/2022	6/14/2022	515 Gleason Pkwy.	50,000		Reclaimed Water	Equipment (ARV)	SW (Barkentine Canal)
6/4/2022	6/7/2022	1140 SE 32nd Terr.	200	250	Raw Water	LS-200 capacity exceeded due to TS Alex, Equipment	Ground
4/4/2022	4/4/2022	3829 Pelican Blvd.	50	0	Raw Water	LS-480 failure of 3 float switches, Equipment	Ground
2/18/2022	2/18/2022	241 SW 24th Ave.	1,800	1,500	Raw Water	Line Break	SW (Shadroe Canal)
2/16/2022	2/17/2022	1220 Tropicana Pkwy. LS-617	5,000	4,600	Raw Water	Bypass pump hose failure LS-617, Equipment	NA
12/16/2021	12/16/2021	4402 SW 8th Ct.	10,000	0	Reclaimed Water	Corp stop damaged by Contractor	NA
11/12/2021	11/13/2021	1101 NE 7th St.	800	25,000	Raw Water	Line Break	Ground
10/26/2021	10/27/2021	812 SE 34th St.	300	1,000	Raw Water	Line Break	Santa Fe Canal (SW)
10/17/2021	10/18/2021	3501 Del Prado Blvd.	15,000	22,000	Raw Water	Line Break	Glen Cove Canal (SW)
10/11/2021	10/12/2021	2905 SE Santa Barbara Pl.	300	400	Reclaimed Water	Line Break	Anchor Canal (SW)
9/20/2021	9/21/2021	1199 SW 57th Pl.	20	0	Raw Water	Equipment (ARV)	Casaba & Citrus Canal

8/31/2021	9/1/2021	1832 Hancock Bridge Pkwy.	200	0	Reclaimed Water	Line Break	Ground
8/27/2021	8/28/2021	4711 Academy Blvd.	400	0	Reclaimed Water	Line Break	Ground
7/8/2021	7/8/2021	2710 Ceitus Pkwy.	20	20	Raw Water	Equipment (ARV)	Ground
7/7/2021	7/8/2021	1140 SE 32nd Terr.	500	1,000	Raw Water	I & I	Stormwater, ground
6/10/2021	6/11/2021	2401 SW 24th St.	20	500	Raw Water	Possibly damaged by directional drilling Contractor	Stormwater, ground
4/12/2021	4/13/2021	509 NE 7th Pl.	900	2,200	Raw Water	Home construction contractor damaged ARV Accident (ARV)	Ground
12/21/2020	12/21/2020	519 Chiquita Blvd.	1,175	0	Reclaimed Water	Force Main damaged by directional drill Contractor	Ground
10/28/2020	10/28/2020	510 NE 7th Pl.	350	350	Raw Water	Accident (ARV)	Ground
8/20/2020	8/21/2020	614 SE 46th St.	75	0	Raw Water	Line Break	Ground
4/30/2020	5/5/2020	659 NE 7th Pl.	12,400	25,000	Raw Water	Contractor	Arrowhead Lake (SW); stormwater; ground
4/8/2020	4/9/2020	SW 49th Terr. & Chiquita Blvd.	40,000	0	Reclaimed Water	Irrigation Main damaged by directional drill Contractor	Orion Canal (SW); stormwater; ground

3/20/2020	3/21/2020	1740 Everest Pkwy.	200,000	200,000	Raw Water	Contractor	Ground
2/17/2020	2/18/2020	1420 Gleason Pkwy.	4,000	0	Reclaimed Water	Line Break	Stormwater; ground
1/31/2020	1/31/2020	1926 SW 30th Terr.	500	1,300	Raw Water	ARV damaged by mowing Contractor	Stormwater; ground
1/3/2020	1/3/2020	1600 Cape Coral Pkwy. E.	400		Raw Water	Gravity line Blockage	Ground
			Total Volume (gal) =	1,402,007	331,220	RW Dist 3-yr	
			Total Raw Volume (gal) =	297,535	330,820	33,698,790,000	0.003277 %
			Total RC Volume (gal) =	1,104,272	400	21.2	
						78.8	62.9
			O&M Total Raw Volume (gal) =	32,195	2.30		%

Reclaimed Water Event Dates			SSO Volume (gal.)	Recovered Volume (gal.)
	Total Volume (gal) =		1,402,007	331,220
9/15/2022	Total Raw Volume (gal) =		297,535	330,820
9/10/2022	Total RC Volume (gal) =		1,104,272	400
7/13/2022				
6/7/2022				
12/16/2021				
10/11/2021				
8/31/2021				
8/27/2021				
12/21/2020				
4/8/2020				
2/17/2020				

Cleanup Actions	State Watch Office #	Have SSO Report Copy	Notes	SSO Report Document ID	Range of Reclaimed to Canal Water Blend (%)
Washdown, Sampling			SSO reported to UCD/WRF and repaired 9/4/23, reported to FDEP 9/5/23.	20230904 4 SE 21st Ave S SSO Rpt	
Vacuum recovery, lime treatment, washdown		Yes	SSO reported to UCD/WRF and repaired 7/17/23, reported to FDEP 7/17/23.	20230717 6 Burnt Store Rd SSO Rpt	
Vacuum recovery, lime treatment, canal sampling		Yes	US Water on site performing work 6/14/23, reported to FDEP 6/14/23.	20230614 4901 Normandy Ct SSO Rpt	
Vacuum recovery, lime treatment		Yes	SSO reported to UCD/WRF and repaired 3/7/23, reported to FDEP 3/8/23.	20230307 917 NE Pine Island Ln SSO Rpt	
Lime treatment, washdown, site cleanup		Yes	SSO reported to UCD/WRF and repaired 2/23/23, reported to FDEP 2/23/23.	20230223 400 W Kennedy Lake Dr SSO Rpt	
Vacuum recovery, lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF and repaired 11/7/22, reported to FDEP 11/8/22.	20221107 3014 Chiquita Blvd SSO Rpt	
Vacuum recovery, lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF 10/15/22, repaired and reported to FDEP 10/16/22.	20221015 4318 SW 9th Ave SSO Rpt	
Replaced displaced earth	2022-7219	Yes	SSO reported to UCD/WRF and repaired 9/15/22, reported to FDEP 9/16/22.	20220915 423 SE 26th Terr SSO Rpt	99 to 100
Repair, sample	2022-7026	Yes	SSO reported to UCD/WRF and repaired 9/10/22, reported to FDEP 9/11/22.	20220910 4411 Skyline Blvd SSO Rpt	36 to 90
Vacuum recovery, lime treatment, washdown	2022-5858	Yes	SSO reported to UCD/WRF, repaired and reported to FDEP 8/3/22.	20220803 4901 Del Prado Blvd SSO Rpt	
Vacuum recovery, lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF, portable bypass pump installed 7/31/22, reported to FDEP 8/1/22.	20220731 1600 Cape Coral Pkwy SSO Rpt	

Samples	2022-5257	Yes	Atlas Underground reported SSO to UCD/WRF and repaired 7/13/22, reported to FDEP 7/14/22, current SSO report indicates 432,000 gal. discharged.	20220713 1803 Cape Coral PkwY SSO Rpt	46 to 58
Vacuum recovery, washdown	NA	Yes	SSO reported to UCD/WRF, repaired and reported to FDEP 6/27/22.	20220627 1003 Santa Barbara Blvd SSO Rpt	
Repair, Samples	2022-4106	Yes	SSO reported to UCD/WRF, repaired and reported to FDEP 6/7/22.	20220607 515 Gleason PkwY SSO Rpt	100
Vacuum recovery, lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF 6/4/22, responded, repaired and reported to FDEP 6/5/22.	20220604 1140 SE 32nd Terr SSO Rpt	
Lime treatment, repair	2022-0996	Yes	SSO reported to UCD/WRF, repaired and reported to FDEP 4/4/22.	20220404 3829 Pelican Blvd SSO Rpt	
Vacuum recovery, lime treatment, repair, samples	2022-0958	Yes	SSO reported to UCD/WRF, repaired and reported to FDEP 2/18/22.	20220218 241 SW 24th Ave SSO Rpt	
Vacuum recovery, lime treatment	2022-0958	Yes	SSO reported to UCD/WRF, responded and repaired 2/16/22, reported to FDEP 2/17/22.	20220216 1220 Tropicana PkwY SSO Rpt	
Repair	2021-7104	Yes	SSO reported to UCD/WRF, responded, repaired and reported to FDEP 12/16/21.	20211216 4402 SW 8th Ct SSO Rpt	39 to 53
Vacuum recovery, lime treatment, washdown, repair	NA	Yes	SSO reported to UCD/WRF 11/12/21, responded and repair completed and reported to FDEP 11/13/21.	20211112 1011 NE 7th St SSO Rpt	
Vacuum recovery, lime treatment, repair, samples	2021-6128	Yes	SSO reported to UCD/WRF, responded and repaired 10/26/21, reported to FDEP 10/27/21.	20211026 812 SE 34th St SSO Rpt	
Vacuum recovery, lime treatment, repair, samples	2021-5957	Yes	SSO reported to UCD/WRF and responded 10/17/21, repaired and reported to FDEP 10/18/21.	20211017 3501 Del Prado Blvd SSO Rpt	
Vacuum recovery, wash, repair, samples	NA	Yes	SSO reported to UCD/WRF, responded and repaired 10/11/21, reported to FDEP 10/12/21.	20211011 2905 Santa Barbara Pl SSO Rpt	100
Repair, samples	NA	Yes	SSO reported to UCD/WRF, responded and repaired 9/20/21, reported to FDEP 9/21/21.	20210920 1199 SW 57th Pl SSO Rpt	

Repair	NA	Yes	SSO reported to UCD/WRF, responded and repaired 8/31/21, reported to FDEP 9/1/21.	20210831 1832 Hancock Bridge Pkwy SSO Rpt	100
Wash, repair	NA	Yes	SSO reported to UCD/WRF, responded and repaired 8/27/21, reported to FDEP 8/28/21.	20210827 4711 Academy Blvd SSO Rpt	78 to 100
Vacuum recovery, wash	NA	Yes	SSO reported to UCD/WRF, responded, repaired and reported to FDEP 7/8/21.	20210708 2710 Ceitus Pkwy SSO Rpt	
Vacuum recovery, lime treatment, washdown, repair	NA	Yes	SSO reported to UCD/WRF, responded and repaired 7/7/21, reported to FDEP 7/8/21.	20210707 1140 SE 32nd Terr SSO Rpt	
Vacuum recovery, lime treatment, washdown, repair	2021-2999	Yes	SSO reported to UCD/WRF and responded 6/10/21, reported to FDEP 6/11/21, final repairs completed 6/14/21, SSO report indicates 50 gal discharged.	20210610 2401 SW 24th St SSO Rpt	
Vacuum recovery, lime treatment, repair	NA	Yes	SSO reported to UCD/WRF, responded and repaired 4/12/21, reported to FDEP 4/13/21.	20210412 509 NE 7th Pl SSO Rpt	
Repair	2020-7024	Yes	SSO reported to UCD/WRF, responded and repaired 12/21/20, reported to FDEP 12/22/20.	20201221 519 Chiquita Blvd SSO Rpt	100
Vacuum recovery, lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF, responded, repaired and reported to FDEP 10/28/20.	20201028 510 NE 7th Pl SSO Rpt	
Lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF, responded and repaired 8/20/20, reported to FDEP 8/20/20. SSO report indicates that LS-305 EPO line cap blew off of camlok fitting.	20200820 614 SE 46th St SSO Rpt	
Vacuum recovery, washdown, repair, sampling	2020-2237	Yes	SSO reported to UCD/WRF, responded and repaired 4/30/20, reported to FDEP 5/1/20.	20200430 659 NE 7th Pl SSO Rpt	
Washdown, repair	2020-1914	Yes	SSO reported to UCD/WRF, responded and repaired 4/8/20, reported to FDEP 4/9/20.	20200408 SW 49th Terr - Chiquita Blvd SSO Rpt	11 to 15

Vacuum recovery, washdown, repair	2020-1644	Yes	SSO reported to UCD/WRF, responded and repaired 3/20/20, reported to FDEP 3/21/20. Tank demolition contractor damaged 12" force main at WRF site.	20200320 1740 Everest Pkwy SSO Rpt	
Repair	2020-1019	Yes	SSO reported to UCD/WRF, responded and repaired 12/17/20, reported to FDEP 12/18/20. SSO report indicates 3" reuse main damaged during construction.	20200217 1420 Gleason Pkwy SSO Rpt	63 to 100
Vacuum recovery, lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF, responded, repaired and reported to FDEP 1/31/20.	20200131 1926 SW 30th Terr SSO Rpt	
Lime treatment, washdown	NA	Yes	SSO reported to UCD/WRF, responded and repaired 1/2/20, reported to FDEP 1/3/20.	20200103 1600 Cape Coral Pkwy SSO Rpt	

Totals =

SSO Report Count	Compiled SSO Report Count	Reclaimed Water Count	Raw Water Count
---------------------	---------------------------------	-----------------------------	--------------------

1	1		
---	---	--	--

1	1		
---	---	--	--

1	1		1
---	---	--	---

1	1		1
---	---	--	---

1	1		1
---	---	--	---

--	--	--	--

1	1		1
---	---	--	---

1	1		1
---	---	--	---

1	1	1	
---	---	---	--

1	1	1	
---	---	---	--

1	1		1
---	---	--	---

1	1		1
---	---	--	---

1 1 1

1 1 1

1 1 1

1 1 1



1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1 1 1

1	1		1
---	---	--	---

1	1	1	
---	---	---	--

1	1		1
---	---	--	---

1	1		1
---	---	--	---

39	39	11	26
----	----	----	----

September 15, 2022, Canal Pump Stations, Water Reclamation Facilities and Reclaimed Water Source Hourly Pumping Summary

[illegible]

September 10, 2022, Canal Pump Stations, Water Reclamation Facilities and Reclaimed Water Source Hourly Pumping Summary

[illegible]

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Canal Pump Station-10 (gal.)	Entrada Reservoir (FGUA) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)		Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)
JUL 13, 2022	TIME																	
JUL 13, 2022	00:00	0	0	0	0	146,181	0	164,269	530,139	1,208,695								
JUL 13, 2022	01:00	0	0	0	204,073	383,758	0	168,332	530,139	1,249,697								
JUL 13, 2022	02:00	0	0	0	372,693	393,445	0	144,691	1,003,598	1,230,610								
JUL 13, 2022	03:00	0	0	0	367,664	380,903	0	121,350	1,254,054	1,156,819								
JUL 13, 2022	04:00	116,398	108,227	90,143	411,148	394,853	0	135,097	1,234,111	870,397								
JUL 13, 2022	05:00	337,442	230,812	258,550	366,407	379,374	0	124,246	1,184,216	624,141								
JUL 13, 2022	06:00	329,831	196,297	5,593	364,464	330,315	4,139	134,081	1,184,216	367,568								
JUL 13, 2022	07:00	306,787	89,462	0	223,114	150,092	43,113	123,241	1,004,036	8,802								
JUL 13, 2022	08:00	53,421	0	0	21,632	0	0	132,454	961,507	0								
JUL 13, 2022	09:00	0	0	0	0	0	0	125,085	749,906	0								
JUL 13, 2022	10:00	0	0	0	0	0	0	85,431	479,667	0								
JUL 13, 2022	11:00	0	0	0	0	0	0	77,374	331,569	0								
JUL 13, 2022	12:00	0	0	0	0	0	0	86,277	305,240	0								
JUL 13, 2022	13:00	0	0	0	16,893	0	0	90,190	201,787	0								
JUL 13, 2022	14:00	0	0	170,360	174,781	0	0	94,688	201,787	0		2:19		345,141	54	296,475	46	641,616
JUL 13, 2022	15:00	0	0	86,925	121,866	0	0	94,000	192,074	0				208,791	42	286,074	58	494,865
JUL 13, 2022	16:00	0	0	48,161	72,667	0	0	124,144	0	0			3:20	120,828	49	124,144	51	244,972
JUL 13, 2022	17:00	0	0	47,230	86,954	0	0	126,223	0	0								
JUL 13, 2022	18:00	0	0	47,069	93,255	0	0	127,403	0	0								
JUL 13, 2022	19:00	0	0	50,610	121,734	0	0	127,680	0	0								
JUL 13, 2022	20:00	0	0	330,693	129,357	0	160,503	127,680	0	0								
JUL 13, 2022	21:00	0	0	438,066	98,075	4	156,199	127,680	0	0								
JUL 13, 2022	22:00	0	0	430,435	103,616	0	158,498	119,538	129,613	0								
JUL 13, 2022	23:00	0	0	309,434	84,480	4	86,611	119,400	0	0								
	24 HR TOTAL	1,143,878	624,799	2,313,269	3,434,873	2,558,928	609,064	2,900,554	11,477,659	6,716,730	Total Flow (gal.) 31,779,754							
TOTALS	8am to midnight	53,421	0	1,958,984	1,125,310	7	561,811											

June 7, 2022, Canal Pump Stations, Water Reclamation Facilities and Reclaimed Water Source Hourly Pumping Summary

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Canal Pump Station-10 (gal.)	Entrada Reservoir (FGUA) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)		Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)	
JUN 07, 2022	TIME																		
JUN 07, 2022	00:00	0	0	0	0	0	0	145,118	194,141	1,492,729									
JUN 07, 2022	01:00	0	0	0	0	0	0	157,774	275,406	1,674,491									
JUN 07, 2022	02:00	0	0	0	0	0	0	164,983	373,170	1,661,901									
JUN 07, 2022	03:00	0	0	0	0	0	0	160,856	459,518	1,578,542									
JUN 07, 2022	04:00	0	0	0	0	0	0	147,620	463,173	1,645,167									
JUN 07, 2022	05:00	0	0	0	0	0	0	133,934	382,925	1,391,596	5:50			0	0	1,908,455	100	1,908,455	
JUN 07, 2022	06:00	0	0	0	0	0	0	118,652	458,706	1,190,636				0	0	1,767,993	100	1,767,993	
JUN 07, 2022	07:00	0	0	0	0	0	0	72,076	344,408	798,386			7:00	0	0	1,214,869	100	1,214,869	
JUN 07, 2022	08:00	0	0	0	0	0	0	136,095	160,533	0									
JUN 07, 2022	09:00	0	0	0	0	4	0	128,433	160,533	0									
JUN 07, 2022	10:00	0	0	0	0	0	0	81,087	106,621	0									
JUN 07, 2022	11:00	0	0	0	0	0	0	72,198	120,658	0									
JUN 07, 2022	12:00	0	0	0	0	0	0	103,385	164,439	0									
JUN 07, 2022	13:00	0	0	0	0	0	0	157,626	163,790	0									
JUN 07, 2022	14:00	0	0	0	0	4	0	154,766	111,434	0									
JUN 07, 2022	15:00	0	0	0	0	0	0	119,820	0	0									
JUN 07, 2022	16:00	0	0	0	0	0	0	108,040	0	0									
JUN 07, 2022	17:00	0	0	0	0	0	0	110,646	82,762	0									
JUN 07, 2022	18:00	0	0	0	0	0	0	118,990	92,446	0									
JUN 07, 2022	19:00	0	0	0	0	0	0	127,066	76,147	0									
JUN 07, 2022	20:00	0	0	0	0	4	0	138,230	55,684	0									
JUN 07, 2022	21:00	0	0	0	0	0	0	139,156	46,122	0									
JUN 07, 2022	22:00	0	0	0	0	0	0	140,824	80,562	0									
JUN 07, 2022	23:00	0	0	0	0	0	0	133,765	114,102	417,565									
24 HR TOTAL		0	0	0	0	11	0	3,071,140	4,487,277	11,851,013									
TOTALS 8am to midnight		0	0	0	0	11	0	1,970,127	1,535,831	417,565									
												Total Flow (gal.)							
												19,409,441							
												Total Flow (gal.)							
												3,923,534							
												Total Flow Canals							
												Only (gal.)							
												11							
Canal Backfill	0																		
Everest Potable	0																		
Southwest Potable	0																		

December 16, 2021, Canal Pump Stations, Water Reclamation Facilities and Reclaimed Water Source Hourly Pumping Summ:

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Canal Pump Station-10 (gal.)	Entrada Reservoir (FGU/A) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)	Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)
TIME	DEC 16, 2021																
00:00	DEC 16, 2021	639,533	515,384	437,216	353,223	355,206	629,732	127,687	20,000	942,000							
01:00	DEC 16, 2021	659,759	532,452	489,149	370,420	401,480	643,322	150,810	520,000	937,000							
02:00	DEC 16, 2021	600,005	500,432	491,146	357,563	392,936	631,674	104,857	1,120,000	897,000							
03:00	DEC 16, 2021	802,531	519,336	490,823	363,683	402,044	647,113	96,269	870,000	909,000							
04:00	DEC 16, 2021	929,014	530,730	494,892	394,215	405,973	652,159	96,141	760,000	919,000							
05:00	DEC 16, 2021	586,907	499,753	484,303	318,117	381,669	589,027	108,883	760,000	868,000							
06:00	DEC 16, 2021	76,660	480,140	454,681	295,180	48,781	393,827	126,873	710,000	723,000							
07:00	DEC 16, 2021	355,553	401,777	0	231,427	0	0	137,468	510,000	288,000							
08:00	DEC 16, 2021	8,986	49,023	0	1,921	0	0	128,735	510,000	0							
09:00	DEC 16, 2021	0	0	0	0	0	0	109,190	290,000	0							
10:00	DEC 16, 2021	0	181,789	0	0	0	0	87,090	290,000	0							
11:00	DEC 16, 2021	0	172,811	0	0	0	0	79,565	0	0							
12:00	DEC 16, 2021	0	158,628	0	0	0	0	80,163	0	0							
13:00	DEC 16, 2021	0	145,906	0	0	0	0	80,014	0	0							
14:00	DEC 16, 2021	0	120,279	0	0	11	0	85,840	0	0	2:15		120,290	58	85,840	42	206,130
15:00	DEC 16, 2021	0	126,737	0	0	0	0	97,596	0	0			126,737	56	97,596	44	224,333
16:00	DEC 16, 2021	0	112,609	0	0	0	0	125,299	0	0			112,609	47	125,299	53	237,908
17:00	DEC 16, 2021	0	156,811	0	0	0	0	119,216	0	0			156,811	57	119,216	43	276,027
18:00	DEC 16, 2021	0	180,087	0	0	0	0	113,209	0	0	6:30		180,087	61	113,209	39	293,296
19:00	DEC 16, 2021	0	201,278	0	0	0	0	116,156	0	0							
20:00	DEC 16, 2021	0	223,216	0	0	0	0	118,602	0	0	Range during reclaimed water SSO event						
21:00	DEC 16, 2021	0	232,195	0	0	0	0	117,888	0	0							
22:00	DEC 16, 2021	98,435	243,693	0	0	0	0	125,564	0	0							
23:00	DEC 16, 2021	170,178	81,682	99,823	77,381	98,020	298,973	103,950	0	514,000							
24 HR TOTAL		4,927,562	6,366,747	3,442,032	2,763,130	2,486,118	4,485,828	2,637,065	6,360,000	6,997,000							
											Total Flow (gal.)						
											40,465,482						
											Total Flow (gal.)						
											6,532,550						
											Total Flow Canals						
											Only (gal.)						
											24,471,417						
TOTALS 8am to midnight		277,600	2,386,745	99,823	79,301	98,031	298,973	1,688,077	1,090,000	514,000							
Canal Backfill		0															
Everest Potable		0															
Southwest Potable		0															

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Canal Pump Station-10 (gal.)	Entrada Reservoir (FGUA) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)		Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)
TIME	OCT 11, 2021																	
00:00	OCT 11, 2021	0	0	0	146,287	0	184,120	147,444	264,057	1,413,301								
01:00	OCT 11, 2021	104,548	0	0	356,258	70,739	202,893	134,737	898,820	1,360,885								
02:00	OCT 11, 2021	305,868	0	0	552,557	252,810	94,890	130,816	898,820	1,249,465								
03:00	OCT 11, 2021	294,593	0	0	511,946	374,536	64,844	143,028	1,082,184	1,132,356								
04:00	OCT 11, 2021	327,588	0	0	643,891	397,646	87,133	140,361	1,082,184	1,180,124								
05:00	OCT 11, 2021	331,201	0	0	607,569	389,974	78,846	137,042	962,764	985,159								
06:00	OCT 11, 2021	211,200	0	0	532,527	249,299	63,452	133,570	1,137,258	800,425								
07:00	OCT 11, 2021	0	0	0	426,487	0	47,088	124,705	1,082,936	498,363								
08:00	OCT 11, 2021	0	0	0	69,064	0	7,711	105,961	914,531	0								
09:00	OCT 11, 2021	0	0	0	0	4	0	120,713	544,909	0								
10:00	OCT 11, 2021	0	0	0	0	0	0	128,618	372,226	0								
11:00	OCT 11, 2021	0	0	0	0	0	0	154,023	200,364	0								
12:00	OCT 11, 2021	0	0	0	0	0	0	162,268	126,251	0								
13:00	OCT 11, 2021	0	0	0	0	0	0	136,481	27,557	0								
14:00	OCT 11, 2021	0	0	0	0	0	0	143,629	74,880	0	2:00			0	0	218,509	100	218,509
15:00	OCT 11, 2021	0	0	0	0	0	0	149,948	51,656	0		3:00		0	0	201,604	100	201,604
16:00	OCT 11, 2021	0	0	0	0	0	403	144,762	52,732	0								
17:00	OCT 11, 2021	0	0	0	0	0	1,886	158,918	57,405	0								
18:00	OCT 11, 2021	0	0	0	0	0	7,967	160,743	57,405	0								
19:00	OCT 11, 2021	0	0	0	0	0	10,156	161,444	84,906	0								
20:00	OCT 11, 2021	0	0	0	0	0	9,899	163,409	84,906	0								
21:00	OCT 11, 2021	0	0	0	0	4	9,991	166,666	125,162	0								
22:00	OCT 11, 2021	0	0	0	0	0	7,866	174,177	156,463	37,678								

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Canal Pump Station-10 (gal.)	Entrada Reservoir (FGUA) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)		Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)
TIME	AUG 31, 2021																	
00:00	AUG 31, 2021	0	0	0	0	0	0	121,347	261,938	360,552								
01:00	AUG 31, 2021	0	0	0	0	0	0	124,784	439,045	489,791								
02:00	AUG 31, 2021	0	0	0	0	0	0	135,080	452,213	496,118								
03:00	AUG 31, 2021	0	0	0	0	0	0	141,420	494,967	480,100								
04:00	AUG 31, 2021	0	0	0	0	0	0	134,778	494,967	472,369								
05:00	AUG 31, 2021	0	0	0	0	0	0	125,523	412,657	487,230								
06:00	AUG 31, 2021	0	0	0	0	0	0	126,396	224,075	115,499								
07:00	AUG 31, 2021	0	0	0	0	0	0	141,898	205,058	155,270								
08:00	AUG 31, 2021	0	0	0	0	0	0	130,458	35,355	0								
09:00	AUG 31, 2021	0	0	0	0	0	0	137,542	36,034	0								
10:00	AUG 31, 2021	0	0	0	0	0	0	105,868	52,800	0								
11:00	AUG 31, 2021	0	0	0	0	0	0	100,472	52,800	0								
12:00	AUG 31, 2021	0	0	0	0	0	0	98,062	107,070	0								
13:00	AUG 31, 2021	0	0	0	0	7	0	95,773	109,249	0								
14:00	AUG 31, 2021	0	0	0	0	0	0	92,494	92,818	0								
15:00	AUG 31, 2021	0	0	0	0	0	0	73,229	110,446	0								
16:00	AUG 31, 2021	0	0	0	0	0	0	76,515	131,011	0								
17:00	AUG 31, 2021	0	0	0	0	0	0	131,235	146,505	0	5:00			0	0	277,740	100	277,740
18:00	AUG 31, 2021	0	0	0	0	0	0	127,549	107,997	0		5:30		0	0	235,546	100	235,546
19:00	AUG 31, 2021	0	0	0	0	0	0	129,300	110,070	0								
20:00	AUG 31, 2021	0	0	0	0	0	0	132,672	126,991	0	Range during reclaimed water SSO event							
21:00	AUG 31, 2021	0	0	0	0	0	0	127,326	176,662	0					0		100	
22:00	AUG 31, 2021	0	0	0	0	0	0	122,754	220,052	0					Average =	0	100	
23:00	AUG 31, 2021	0	0	0	0	0	0	124,470	274,828	26,470								

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Canal Pump Station-10 (gal.)	Entrada Reservoir (FGUA) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)		Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)
TIME	AUG 27, 2021																	
00:00	AUG 27, 2021	0	2,096	0	158,734	0	0	164,917	172,260	944,907								
01:00	AUG 27, 2021	0	87,920	0	191,373	0	0	178,253	898,761	977,701								
02:00	AUG 27, 2021	0	156,342	39,269	191,010	7	0	179,160	1,048,697	975,930								
03:00	AUG 27, 2021	0	162,945	249,585	174,975	0	0	179,160	1,048,697	936,938								
04:00	AUG 27, 2021	0	156,546	264,103	192,700	0	0	179,160	976,853	1,001,570								
05:00	AUG 27, 2021	0	156,601	261,566	186,751	0	0	179,160	630,148	981,343								
06:00	AUG 27, 2021	346,854	175,561	469,360	227,109	123,640	0	175,827	808,779	379,104								
07:00	AUG 27, 2021	554,277	167,880	142,450	0	28,534	0	146,807	786,161	237,698								
08:00	AUG 27, 2021	5,302	268,921	0	0	0	0	102,953	323,208	0								
09:00	AUG 27, 2021	0	8,514	0	0	0	0	48,866	406,704	0								
10:00	AUG 27, 2021	0	0	0	0	0	0	96,622	186,408	0								
11:00	AUG 27, 2021	0	0	0	0	0	0	96,691	186,408	0								
12:00	AUG 27, 2021	0	0	0	0	0	0	85,692	123,504	0								
13:00	AUG 27, 2021	0	0	0	0	0	0	76,340	111,802	0								
14:00	AUG 27, 2021	0	0	0	0	0	0	100,476	115,979	0								
15:00	AUG 27, 2021	0	0	0	0	0	0	139,115	63,932	0								
16:00	AUG 27, 2021	0	0	0	0	0	0	140,034	0	0								
17:00	AUG 27, 2021	0	0	0	0	7	0	152,614	0	0	5:30			7	0	152,614	100	152,621
18:00	AUG 27, 2021	0	14,178	0	0	0	0	141,129	0	0				14,178	9	141,129	91	155,307
19:00	AUG 27, 2021	0	35,613	0	0	0	0	130,389	0	0				35,613	21	130,389	79	166,002
20:00	AUG 27, 2021	0	42,181	0	0	0	0	145,614	0	0			8:30	42,181	22	145,614	78	187,795
21:00	AUG 27, 2021	0	67,918	0	0	0	0	140,746	0	0								
22:00	AUG 27, 2021	0	85,041	0	0	4	0	117,356	0	0		</						

December 21, 2020, Canal Pump Stations, Water Reclamation Facilities and Reclaimed Water Source Hourly Pumping Summary

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Entrada Reservoir (FGUA) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)					Reclaimed Hourly Totals (gal.)	Percent Flow Blend	Reclaimed Flow Blend	Percent Flow Blend
TIME										Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend				
00:00	DEC 21, 2020	278,868	223,666	116,833	285,438	375,090	100,242	880,000	700,000								
01:00	DEC 21, 2020	170,563	94,717	239,348	230,393	388,827	100,242	810,000	900,000								
02:00	DEC 21, 2020	78,538	8,699	236,338	175,708	368,489	100,242	810,000	890,000								
03:00	DEC 21, 2020	100,098	15,406	236,976	179,560	378,374	100,242	820,000	880,000								
04:00	DEC 21, 2020	264,585	0	237,588	256,186	385,235	100,242	800,000	880,000								
05:00	DEC 21, 2020	56,321	0	236,159	117,031	321,750	100,242	750,000	1,010,000								
06:00	DEC 21, 2020	0	0	161,267	10,486	132,517	100,242	540,000	950,000								
07:00	DEC 21, 2020	0	0	0	0	0	100,242	180,000	310,000								
08:00	DEC 21, 2020	0	0	0	0	0	100,242	180,000	0								
09:00	DEC 21, 2020	0	0	0	0	0	100,242	190,000	0								
10:00	DEC 21, 2020	0	0	0	0	7	100,242	190,000	0								
11:00	DEC 21, 2020	0	0	0	0	0	100,242	110,000	0								
12:00	DEC 21, 2020	0	0	0	0	0	100,242	110,000	0	12:00		0	0	210,242	100	210,242	
13:00	DEC 21, 2020	0	0	0	0	0	100,242	110,000	0		1:00	0	0	210,242	100	210,242	
14:00	DEC 21, 2020	0	0	0	0	0	100,242	90,000	0	Range during reclaimed water SSO event							
15:00	DEC 21, 2020	0	0	0	0	0	100,242	90,000	0								
16:00	DEC 21, 2020	0	0	0	0	0	100,242	60,000	0	Minimum = 0 100							
17:00	DEC 21, 2020	0	0	0	0	0	100,242	60,000	0	Average = 0 100							
18:00	DEC 21, 2020	0	0	0	0	0	100,242	70,000	0	Maximum = 0 100							
19:00	DEC 21, 2020	0	0	0	0	0	100,242	70,000	0								
20:00	DEC 21, 2020	0	0	0	0	0	100,242	90,000	0								
21:00	DEC 21, 2020	0	0	0	0	0	100,242	120,000	0								
22:00	DEC 21, 2020	98,461	0	0	0	112,629	100,242	190,000	40,000								
23:00	DEC 21, 2020	0	0	0	0	0	100,242	190,000	300,000								
24 HR TOTAL		1,047,434	342,488	1,464,509	1,254,803	2,462,918	2,405,808	7,510,000	6,860,000	Total Flow (gal.) 23,347,960							
TOTALS 8am to midnight		98,461	0	0	0	112,637	1,603,872	1,920,000	340,000	Total Flow (gal.) 4,074,970							
		Total Flow Canals Only (gal.) 6,572,152															
Entrada Total Flow		2,405,805 100,242	0 6,572,152														
Canal Backfill		0	0														
Everest Potable		0	0														
Southwest Potable		0	0														

April 8, 2020, Canal Pump Stations, Water Reclamation Facilities and Reclaimed Water Source Hourly Pumping Summary

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Entrada Reservoir (FGU/A) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)		Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)
TIME	APR 08, 2020																
00:00	APR 08, 2020	572,783	606,024	407,058	372,088	394,688	79,157	0	260,000								
01:00	APR 08, 2020	903,261	630,887	590,346	600,143	59,399	79,157	0	860,000								
02:00	APR 08, 2020	945,201	591,766	608,056	649,151	0	79,157	470,000	900,000								
03:00	APR 08, 2020	944,775	562,655	506,122	590,019	0	79,157	760,000	730,000								
04:00	APR 08, 2020	986,259	554,430	567,020	614,738	0	79,157	810,000	950,000								
05:00	APR 08, 2020	990,000	546,905	553,334	639,867	0	79,157	1,070,000	950,000								
06:00	APR 08, 2020	963,528	520,873	470,859	543,926	0	79,157	1,070,000	900,000								
07:00	APR 08, 2020	217,302	450,465	373,987	361,330	346,112	79,157	890,000	790,000								
08:00	APR 08, 2020	18,963	206,478	348,601	177,911	115,363	79,157	630,000	0								
09:00	APR 08, 2020	0	0	340,270	0	65,351	79,157	10,000	0								
10:00	APR 08, 2020	0	0	315,658	0	76,875	79,157	10,000	0								
11:00	APR 08, 2020	0	0	276,942	0	77,908	79,157	0	0								
12:00	APR 08, 2020	0	0	283,070	0	14,522	79,157	0	0								
13:00	APR 08, 2020	0	0	300,986	0	773	79,157	0	0								
14:00	APR 08, 2020	0	0	392,899	0	0	79,157	0	0								
15:00	APR 08, 2020	0	0	453,094	0	0	79,157	0	0								
16:00	APR 08, 2020	313,495	5,240	332,313	0	10,977	79,157	0	0	4:30			662,025	89	79,157	11	741,182
17:00	APR 08, 2020	341,065	0	179,710	0	0	79,157	0	0				520,775	87	79,157	13	599,932
18:00	APR 08, 2020	261,490	0	187,407	0	29	79,157	0	0		6:30		448,927	85	79,157	15	528,084
19:00	APR 08, 2020	273,613	0	245,087	0	34,783	79,157	0	0	Range during reclaimed water SSO event							
20:00	APR 08, 2020	343,210	0	233,201	0	101,784	79,157	0	0								
21:00	APR 08, 2020	293,952	0	211,844	0	17,322	79,157	0	0								
22:00	APR 08, 2020	278,170	52,522	118,138	0	75,170	79,157	0	0								
23:00	APR 08, 2020	322,948	121,867	18,476	20,701	181,642	79,157	0	0				Minimum =	85		11	
													Average =	87		13	
													Maximum =	89		15	
	24 HR TOTAL	8,970,015	4,850,111	8,314,479	4,569,874	1,572,700	1,899,768	5,720,000	6,340,000	Total Flow (gal.)							
										42,236,947							
	TOTALS 8am to midnight	2,446,906	386,106	4,237,697	198,612	772,501	1,266,512	650,000	0	Total Flow (gal.)							
										9,958,334							
										Total Flow Canals Only							
										(gal.)							
Entrada Total Flow	1,899,774 79,157									28,277,179							
Canal Backfill	0																
Everest Potable	0																
Southwest Potable	0																

April 8, 2020, Canal Pump Stations, Water Reclamation Facilities and Reclaimed Water Source Hourly Pumping Summary

		Canal Pump Station-2 (gal.)	Canal Pump Station-3 (gal.)	Canal Pump Station-4 (gal.)	Canal Pump Station-5 (gal.)	Canal Pump Station-8 (gal.)	Entrada Reservoir (FGUA) (gal.)	Everest WRF (gal.)	Southwest WRF (gal.)		Time Leak Reported	Time Leak Stopped	CPS Hourly Totals (gal.)	Percent CPS Flow Blend	Reclaimed Hourly Totals (gal.)	Percent Reclaimed Flow Blend	Total Hourly (gal.)
TIME	FEB 17, 2020																
00:00	FEB 17, 2020	333,808	381,265	169,404	417,434	422,676	108,385	290,000	360,000								
01:00	FEB 17, 2020	331,365	391,037	205,620	526,582	438,396	108,385	620,000	810,000								
02:00	FEB 17, 2020	287,049	286,623	184,486	392,624	429,852	108,385	620,000	1,010,000								
03:00	FEB 17, 2020	320,839	334,563	202,930	434,474	443,593	108,385	670,000	1,040,000								
04:00	FEB 17, 2020	337,144	412,931	127,642	519,570	449,553	108,385	640,000	1,090,000								
05:00	FEB 17, 2020	301,054	306,141	0	449,670	411,035	108,385	680,000	1,010,000								
06:00	FEB 17, 2020	164,872	16,010	0	332,199	172,068	108,385	680,000	770,000								
07:00	FEB 17, 2020	0	0	0	119,743	2,313	108,385	690,000	430,000								
08:00	FEB 17, 2020	0	0	0	0	0	108,385	690,000	10,000								
09:00	FEB 17, 2020	0	0	0	0	0	108,385	410,000	0								
10:00	FEB 17, 2020	0	0	0	0	0	108,385	180,000	0	10:45			0	0	288,385	100	288,385
11:00	FEB 17, 2020	117,861	0	0	0	0	108,385	90,000	0				117,861	37	198,385	63	316,246
12:00	FEB 17, 2020	5,738	0	30,249	0	0	108,385	120,000	0				35,987	14	228,385	86	264,372
13:00	FEB 17, 2020	0	0	0	0	9,269	108,385	50,000	0			1:00	9,269	6	158,385	94	167,654
14:00	FEB 17, 2020	0	0	0	0	0	108,385	30,000	0								
15:00	FEB 17, 2020	0	0	0	0	0	108,385	100,000	0								
16:00	FEB 17, 2020	0	0	0	0	0	108,385	120,000	0								
17:00	FEB 17, 2020	0	0	0	0	0	108,385	90,000	0								
18:00	FEB 17, 2020	0	0	0	0	0	108,385	120,000	0								
19:00	FEB 17, 2020	0	0	0	0	0	108,385	120,000	0								
20:00	FEB 17, 2020	0	0	0	0	0	108,385	150,000	0								
21:00	FEB 17, 2020	0	0	0	0	70,248	108,385	170,000	0								
22:00	FEB 17, 2020	0	0	0	0	149,824	108,385	200,000	20,000								
23:00	FEB 17, 2020	0	0	0	0	7	108,385	210,000	190,000								
	24 HR TOTAL	2,199,730	2,128,569	920,331	3,192,297	2,998,835	2,601,240	7,740,000	6,740,000				Total Flow (gal.)		28,521,001		
	TOTALS 8am to midnight	123,599	0	30,249	0	229,349	1,734,160	2,850,000	220,000				Total Flow (gal.)		5,187,357		
													Total Flow Canals Only (gal.)				
Entrada Total Flow	2,601,234 108,385																11,439,761
Canal Backfill	0																
Everest Potable	0																
Southwest Potable	0																